

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Control gear

Name and address of the applicant

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the manufacturer

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the factory

Kontron Electronics
Rákóczi Ferenc utca 78,
8674 Kapoly, Hungary

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

U_{IN}: AC 230-240 V, 50/60 Hz; DC 230 V;
ta: -10 to +60°C; tc: +70°C

Trademark / Brand (if any)

 ZUMTOBEL

--

Customer's Testing Facility (CTF) Stage used

ONLITE central PLC DALI Interface IV

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

For use as built-in, with strain reliefs and terminal cover also useable as independent control gear.

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015
IEC 61347-1:2015/AMD1:2017IEC 61347-2-11:2001
IEC 61347-2-11:2001/AMD1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1012-1

This CB Test Certificate is issued by the National Certification Body




Date: 2020-01-15

Österreichischer Verband für Elektrotechnik

Testing and Certification

Kahlenberger Str. 2A, 1190 Wien, Austria

Digitally signed by W. Martin
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin