



Ref. Certif. No.

AT 5084

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Escape sign emergency luminaire with limited surface temperature

Name and address of the applicant

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the manufacturer

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the factory

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

220-240 V, 50/60 Hz, Cl.I,
IP42 or IP40,

Trademark / Brand (if any)

ZUMTOBEL

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series PURESIGN 150 P MSC...,
see type code on page 3

Additional information (if necessary may also be reported on page 2)

Battery supplied;
Light source classified as RG1(low risk).
See test report for information about National and/or Group Differences.

Additional Information on pages 2 to 4

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2020
IEC 60598-2-22:2021
IEC 60598-2-24:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

TR-251-0178-01, TR-251-0178-02

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

OVE Certification

Kahlenberger Str. 2A, 1190 Wien, Austria

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Signature: Dipl.-Ing. T. Neumayer

Date: 2024-04-23



Ref. Certif. No.

AT 5084

Additional factory:

ZG Lighting SRB doo
Ulica Cumtobel br. 1,
18000 Nis, Serbia

Additional information (if necessary)

Digitally signed by T. Neumayer

Email=t.neumayer@ove.at

Signature: Dipl.-Ing. T. Neumayer

Date: 2024-04-23



Ref. Certif. No.

AT 5084

Typecode:

PURESIGN..... 150 P

Luminaire colour

WH White
BK..... Black
SR Silver

Escape Route Illumination (ERI)

None
ERI

Supply version

E1D ... Emergency 1 hour self-contained DALI
E2D ... Emergency 2 hour self-contained DALI
E3D ... Emergency 3 hour self-contained DALI
E8D ... Emergency 8 hour self-contained DALI

Mounting version

MSC Mounting Surface Ceiling
MSC-WF15..... Mounting Surface Ceiling –
Wire Feed length 1,5m

Luminaire version

Pictogram height

Product family

None for Versions with ERI
/COMSIGN for Versions without ERI

Accessories:

COMSIGN 150 MSW ECx bracket

COMSIGN 150 MSW ExD bracket

PURESIGN/COMSIGN 150 P FCC ExD side feed

PURESIGN/COMSIGN 150 P FCC ECx side feed

PURESIGN/COMSIGN 150 MS90° ExD bracket

PURESIGN/COMSIGN 150 MS90° ECx bracket

PURESIGN/CROSSIGN P ERI SET 20 PCS.

SAFTYSIGNS P BP Grid

Additional information (if necessary)

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Signature: Dipl.-Ing. T. Neumayer

Date: 2024-04-23

Typecode Pictogram:**Escape Route Illumination (ERI)**

None
ERI

Escape direction

None
L, UPL, UP, UPR, R, DR, D, DL, LR, UPLR, DLR
E001 – E099 Evacuation route signs
F001 – F099..... Fire Equipment signs
M001 – M099 Mandatory action signs
P001 – P099 Prohibition signs
W001 – W099 Warning signs

Printed side

1..... One-sided
2..... Double-sided

Reference number ISO 7010

SP E001/E002
WP E026/E030
E001 – E099 Evacuation route signs
F001 – F099..... Fire Equipment signs
M001 – M099 Mandatory action signs
P001 – P099 Prohibition signs
W001 – W099 Warning signs

Mounting version

MSC/MRC
MSC/MRC/TEC-GP
MSC-WF/MRC-WF/MRCR-WF

Pictogram version

None
P

Pictogram height

None
150

Product family

PURE
PURESIGN
COM
COMSIGN

Additional information (if necessary)

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Signature: Dipl.-Ing. T. Neumayer

Date: 2024-04-23