



Ref. Certif. No.

AT 5105

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Escape sign emergency luminaire

Name and address of the applicant

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the manufacturer

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the factory

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

220-240 V; 50/60 Hz; CI.I

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series PURESIGN 150 P TEC-GP ...,
see type code on page 3

Additional information (if necessary may also be
reported on page 2)

Battery supplied;
Light source classified as RG1(low risk).
See test report for information about National and/or Group
Differences.

☒ Additional Information on pages 2 to 4

A sample of the product was tested and found
to be in conformity with

IEC 60598-1:2020
IEC 60598-2-22:2021

As shown in the Test Report Ref. No. which
forms part of this Certificate

TR-251-0176-01

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

OVE Certification

Kahlenberger Str. 2A, 1190 Wien, Austria

T. Neumayer

Digitally signed by T. Neumayer
Email: t.neumayer@ove.at



Signature: Dipl.-Ing. T. Neumayer

Date: 2024-05-21



Ref. Certif. No.

AT 5105

Additional factory:

ZG Lighting SRB doo
Ulica Cumtobel br. 1,
18000 Nis, Serbia

Additional information (if necessary)

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Date: 2024-05-21

Signature: Dipl.-Ing. T. Neumayer

Typecode:

PURESIGN 150 P TEC-GP

Luminaire colour

WH White

BK Black

SR Silver

Supply version

E1D Emergency 1 hour self-contained DALI

E2D Emergency 2 hour self-contained DALI

E3D Emergency 3 hour self-contained DALI

E8D Emergency 8 hour self-contained DALI

Mounting version

TEC-GP .. Mounting on Tecton-System

Luminaire version

Pictogram height

Product family

Additional information (if necessary)

Date: 2024-05-21



Digitally signed by T. Neumayer
Email=t.neumayer@ove.at
Signature: Dipl.-Ing. T. Neumayer

Typecode Pictogram:

PURESIGN ... - ...

Escape direction

None
L, UPL, UP, UPR, R, DR, D, DL, LR, UPLR, DLR
E001 – E099 Evacuation route signs
F001 – F099 Fire Equipment signs
M001 – M099 Mandatory action signs
P001 – P099 Prohibition signs
W001 – W099 Warning signs

Printed side

1 One-sided
2 Double-sided

Reference number ISO 7010

SP E001/E002
WP E026/E030
E001 – E099 Evacuation route signs
F001 – F099 Fire Equipment signs
M001 – M099 Mandatory action signs
P001 – P099 Prohibition signs
W001 – W099 Warning signs

Mounting version

MSC/MRC/TEC-GP

Pictogram version

None
P

Pictogram height

None
150

Product family

Additional information (if necessary)

Date: 2024-05-21


Digitally signed by T. Neumayer
Email: t.neumayer@ove.at
Signature: Dipl.-Ing. T. Neumayer