

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Recessed luminaire

Name and address of the applicant

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the manufacturer

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Name and address of the factory

Zumtobel Lighting GmbH
Schweizer Str. 30,
6850 Dornbirn, Austria

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

220-240 V; 0/50/60 Hz; C.I.I; IP20

Trademark / Brand (if any)

 **ZUMTOBEL**

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series ECOOS2 SLIM...,
see type code on page 42 of test report TR-251-0106-03

Additional information (if necessary may also be reported on page 2)

Light source classified as RG0 (Exempt Group) according to IEC 62471:2006.
Also available as centrally supplied maintained emergency luminaire
(classification Z 1) according to IEC 60598-2-22:2014 + AMD1,
see test report TR-251-0106-04 (optional).☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014
IEC 60598-1:2014/AMD1:2017
IEC 60598-2-2:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

TR-251-0106-03

This CB Test Certificate is issued by the National Certification Body



Ref. Certif. No.

AT 4339

Additional factory:

ZG Lighting SRB doo
Ulica Cumtobel br. 1,
18000 Nis, Serbia, Republic of

Additional information (if necessary)

Date: 2020-03-26

Digitally signed by W. Martin
Email=w.martin@ove.at
Signature: Dipl.-Ing. W. Martin