

OVE Austrian Electrotechnical Association
Eschenbachgasse 9 | 1010 Wien | Austria
ZVR: 327279890 | www.ove.at

OVE Certification
Kahlenberger Str. 2A | 1190 Wien | Austria
T +43 1 370 58 06 | certification@ove.at



ENEC Certification Body registered under ID # 11.

Validity of ENEC Licences can be checked at www.enec.com

LICENCE

to use the European Mark



Licence No.: **251-209**

Date of issue: Wien, 2020 03 20
Rev. No.: 01 Wien, 2024 02 13

OVE the Austrian Electrotechnical Association as signatory to the **"Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards"** hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licensee: **Zumtobel Lighting GmbH**
Schweizer Str. 30
6850 Dornbirn
Austria

Product: **Recessed escape sign emergency luminaire**

Trade Mark:  **ZUMTOBEL**

Series/Type: **ARTSIGN...**

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Österreichischer Verband für Elektrotechnik
Head of OVE Certification



Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



<i>Hersteller Manufacturer</i>	Zumtobel Lighting GmbH Schweizer Str. 30 6850 Dornbirn Austria
<i>Fertigungsstätte(n) Factory location(s)</i>	ZG Lighting SRB doo Ulica Cumtobel br. 1 18000 Nis Serbia Zumtobel Lighting GmbH Schweizer Str. 30 6850 Dornbirn Austria
<i>Typenbezeichnung Type reference</i>	Series ARTSIGN..., see page 5
* <i>Prüfbericht Test Report</i>	TR-251-0174-01 ECS, TR-251-0174-02 ECS, TR-251-0174-03 ECS
* <i>Nationale Bestimmung(en) National Standard(s)</i>	OVE EN IEC 60598-1:2022-04-01 OVE EN IEC 60598-1/A11:2023-02-01 ÖVE/ÖNORM EN 60598-2-2:2012-11-01 OVE EN IEC 60598-2-22:2023-08-01
* <i>Europanorm(en) European Standard(s)</i>	EN IEC 60598-1:2021 EN IEC 60598-1:2021/A11:2022 EN 60598-2-2:2012 EN IEC 60598-2-22:2022
* <i>Ersatz für Zertifikat Superseded licence</i>	251-209 dated 2020 03 20 Items modified are marked with an asterisk (*)
* <i>Anmerkung(en) Remark(s)</i>	--

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

<i>Nennspannung</i> <i>Rated voltage</i>	For centrally supplied types: 220-240 V, 0/50/60 Hz; For battery supplied types: 220-240 V, 50/60 Hz
<i>Anzahl und Leistung der Lampen</i> <i>Rated wattage and number of lamps</i>	1x LEMS6...
* <i>Lampentyp(en)</i> <i>Lamp identification</i>	LED modules
<i>Schutzgrad</i> <i>Degree of protection</i>	IP20/IP40
<i>Netzanschluss</i> <i>Supply connection</i>	Screwless terminals
<i>Befestigungsfläche</i> <i>Supporting surface</i>	Normally flammable surface
<i>Schutzklasse</i> <i>Class of protection</i>	Cl. I
<i>Beschreibung des Aufbaus</i> <i>Description of construction</i>	Escape sign emergency luminaire for fixed recessed installation with metal housing and exit sign cover. The escape sign is digitally printed.
* <i>Zusatzinformation</i> <i>Additional information</i>	Light source classified as RG1(low risk).

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

<i>Bauteil</i> <i>Component</i>	<i>Code</i>	<i>Hersteller</i> <i>Code Manufacturer</i>	<i>Typenbezeichnung</i> <i>Type Reference</i>	<i>Konformitätszeichen</i> <i>Mark(s) of conformity</i>
<i>LED module</i>	A*	Zumtobel	LEM S6...	ÖVE
<i>LED control gear</i>	B	Tridonic	EM powerLED NTx 102 DIM 5W ZUM	ENEC 12
	B	Tridonic	EM powerLED NSI 100 DIM 5W ZUM	ENEC 12
	B	Tridonic	EM powerLED NDA 100 DIM 5W ZUM	ENEC 12
	B	Tridonic	EM powerLED NPS 100 DIM 5W ZUM	ENEC 12
<i>* Battery</i>	A	GP	GP220SCHT; 1,2 V; 2200 mAh; T=50°C	CB (DK-87294-UL)
<i>Terminal</i>	A	Electro Terminal	SLK 3; 450V; 24A; 0,5-2,5 mm²; T110	ENEC 11
	A	Electro Terminal	SLK 5; 450V; 24A; 0,5-2,5 mm²; T85	ENEC 11
<i>Wiring</i>	A	Leoni	Ecosense S05G-U; 300/500 V; 0,5-1 mm²; 110°C	BBJ
	C	Huber + Suhner	RADOX/ UL 3266 / CSA AWM I A/B; 300 V; 0,38-0,96 mm² (AWG22), 125°C	Checked within appliance

A The component is replaceable with another one, also certified, with equivalent characteristics.

A* The component is replaceable with another one according to ETF5-OSM-LUM/DSH 2057.

B The component is replaceable if authorised by the test house.

C Integrated component tested together with the appliance.

D Alternative component.

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode:

ARTSIGN

Pictogram:
None

Escape direction

None
L, UPL, UP, UPR, R, DR, D, DL, LR, UPLR, DLR
E001 – E099 Evacuation route signs
F001 – F099 Fire Equipment signs
M001 – M099 Mandatory action signs
P001 – P099 Prohibition signs
W001 – W099 Warning signs

Printed side

1 One-sided
2 Double-sided

Reference number ISO 7010

SP E001/E002
WP E026/E030
E001 – E099 Evacuation route signs
F001 – F099 Fire Equipment signs
M001 – M099 Mandatory action signs
P001 – P099 Prohibition signs
W001 – W099 Warning signs

Luminaire colour

WH White
BK Black
SR Silver

Supply version

ECC ... Emergency Central battery Circuit
Monitoring
ECD ... Emergency Central battery DALI
ECP ... Emergency Central battery Powerline
E1D ... Emergency 1 hour self-contained DALI
E2D ... Emergency 2 hour self-contained DALI
E3D ... Emergency 3 hour self-contained DALI
E8D ... Emergency 8 hour self-contained DALI

Mounting version

MRC Mounting Recessed Ceiling
MRW Mounting Recessed Wall

Pictogram version

None, P

Pictogram height

None, 75

Product family

OVE Certification


Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Accessories:

ARTSIGN 75 P MRC FSR 12,5 mm
ARTSIGN 75 P MRW FSR 12,5 mm
ARTSIGN 75 P MRC FSR 25 mm
ARTSIGN 75 P MRW FSR 25 mm
ARTSIGN 75 P MSW housing
ARTSIGN 75 P MRC CCS
ARTSIGN 75 P MRW CCS
SAFETYSIGNS P BP Grid

Typecode Pictogram:

ARTSIGN -



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.