

AT 4056

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Fixed general purpose luminaires

Zumtobel Lighting GmbH Schweizer Str. 30, 6850 Dornbirn, Austria

Zumtobel Lighting GmbH Schweizer Str. 30, 6850 Dornbirn, Austria

Zumtobel Lighting GmbH Schweizer Str. 30, 6850 Dornbirn, Austria

☐ Additional Information on page 2

220-240 V; 0/50/60 Hz; CI.I; IP20



ZUMTOBEL

CTF Stage 2

Series ONDA2..., see type code on page 42 of test report TR-251-0086-01

Light source classified as RG0 according to IEC 62471:2006. Also available as centrally supplied maintained emergency luminaire (classification Z 1) according to IEC 60598-2-22:2014, see test report TR-251-0086-03(optional).

☐ Additional Information on page 2

IEC 60598-1:2014 IEC 60598-2-1:1979

IEC 60598-2-1:1979/AMD1:1987

TR-251-0086-01

This CB Test Certificate is issued by the National Certification Body





Österreichischer Verband für Elektrotechnik

Testing & Certification Kahlenberger Str. 2A, 1190 Wien, Austria

Digitally signed by W. Martin Email=w.martin@ove.at ature: Dipl.-Ing. W. Martin



Date: 2018-10-16